

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, KAITHAL



Memo No:- 250

Date - 26/03/2024

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KTL/04716/3/2024	Sample Details	Date & Time
Sample Classification:	Private	Collected By	ST. LAWRENCE EN....9814098235
Sender:	ST. LAWRENCE ENGLISH SCHOOL 29290	Collection Date	22/03/2024 at 08:42
Location:	CHEEKA SAMANA ROAD	Received at lab	22/03/2024 at 10:44
Latitude	76.213210	Tested at Lab	26/03/2024
Longitude :-	30.141205		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C: 2017

Remarks :-

- The Results Given above are related to the sample as received and tested in KAITHAL lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "POTABLE"



SUBHASH CHANDER, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KAITHAL
email:- chemist.kaithal@phedharyana.gov.in

-----End of Report-----

Principal
St. Lawrence English School
Azimgarh, Mehmoodpur P.O.
Distt Kaithal (Haryana) 136034

Chairman
St. Lawrence English School,
Azimgarh, P.O. Mehmoodpur
Distt. Kaithal (Haryana) 13203